



**DECLARATION OF PERFORMANCE**  
**According to Construction Products Regulation EU No. 305/2011**  
**No. 07/06.01.2021**

1. Unique identification code of the product-type:

**FD3050**

**Batch number: see packaging of the product**

2. Intended use/es:

**Fire detection and fire alarm systems installed in buildings.**

**Manual Call Points**

3. Manufacturer:

**UniPOS Ltd.,**

**47 San Stefano Street, 5800, Pleven, Bulgaria**

4. Authorised representative:

**Not relevant**

5. System/s of AVCP:

**System 1**

6. a) Harmonized standard:

**EN 54-11 : 2001 + A1: 2005 - Fire detection and fire alarm systems - Manual call points**

**DBI Certification, notified body No. 2531 performed type testing and the initial inspection of the manufacturing plant and of the factory production control with continuous surveillance assessment and approval of the factory production control under system 1 and issued the EC certificates of conformity:**

**2531-CPR-CSP11240**

7. Declared performance

Essential characteristics	Performance	Harmonized Technical Specification
4.2 Marking and data	Pass	EN54-11: 2001 + A1 :2005
4.3 Frangible element	Pass	EN54-11: 2001 + A1 :2005
4.4 Indicators for alarm condition	Pass	EN54-11: 2001 + A1 :2005
4.5 Reset facility	Pass	EN54-11: 2001 + A1 :2005
4.6 Test facility	Pass	EN54-11: 2001 + A1 :2005
4.7 Construction and design	Pass	EN54-11: 2001 + A1 :2005
4.8 Additional requirements for software controlled manual call points	N/A	EN54-11: 2001 + A1 :2005
5.2 Operational performance test	Pass	EN54-11: 2001 + A1 :2005
5.3 Function test	Pass	EN54-11: 2001 + A1 :2005
5.4 Test facility test (operational)	Pass	EN54-11: 2001 + A1 :2005
5.5 Reliability test (endurance)	Pass	EN54-11: 2001 + A1 :2005
5.6 Variation of supply parameters	Pass	EN54-11: 2001 + A1 :2005
5.7 Dry heat (operational)	Pass	EN54-11: 2001 + A1 :2005
5.8 Dry heat (endurance)	N/A	EN54-11: 2001 + A1 :2005
5.9 Cold (operational)	Pass	EN54-11: 2001 + A1 :2005
5.10 Damp heat, cyclic (operational)	Pass	EN54-11: 2001 + A1 :2005
5.11 Damp heat, cyclic (endurance)	N/A	EN54-11: 2001 + A1 :2005
5.12 Damp heat, steady state (endurance)	Pass	EN54-11: 2001 + A1 :2005
5.13 SO2 corrosion (endurance)	Pass	EN54-11: 2001 + A1 :2005
5.14 Shock (operational)	Pass	EN54-11: 2001 + A1 :2005
5.15 Impact (operational)	Pass	EN54-11: 2001 + A1 :2005
5.16 Vibration, sinusoidal (operational)	Pass	EN54-11: 2001 + A1 :2005
5.17 Vibration, sinusoidal (endurance)	Pass	EN54-11: 2001 + A1 :2005
5.18 Electromagnetic compatibility (EMC) (operational)	N/A	EN54-11: 2001 + A1 :2005

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Hristo Dimitrov, Chief Executive  
(name)

Pleven, 06.01.2021  
(place and date of issue)

Signature \_\_\_\_\_



Chief Executive